

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3225-1411:101 Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: Shoemaker Mfg. Co., 104 Montgomery Ave., Cle Elum, WA 98922
Contact: Jerry Hein (509) 674-4414 FAX (509) 674-4420

DESIGN: Models 2501, -02, -33, -34, -49, -50 and 2601, -02, -33, -34, -49, -50 curtain type fire dampers with 22 ga., 2-5/8" wide galvanized steel interlocking blades in a 22 ga. galvanized steel frame. Models 2549, -50 and 2649, -50 incorporate a round transition collar assembly. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as 1-1/2-hour fire-rated dampers. Approved for installation in the vertical or horizontal position in rectangular or square heating ducts, or in wall openings without ducts not exceeding 59-3/4" in width and 59-3/4" in height when mounted individually, or 119-5/8" in width and 119-5/8" in height when mounted in multiple.

NOTE: Leakage rating not evaluated. Refer to Category 3230 for listed leakage dampers.

07-01-94



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager